

ASTA TYPE CERTIFICATE

VERIFICATION OF TEST

Project No: G104669077LCS004 Certificate No: ASTA-TYPE-0001177

Applicant: Techno Electro Power Industrial W.L.L, Building No. 765, Road 4811, Block No. 948,

Lhassay Area, Manama, Kingdom of Bahrain.

Apparatus: $415V/500V/4kV(U_e/U_i/U_{imp})$, 50Hz switchgear and controlgear assembly incorporating

a three-phase vertical busbar system with brass neutral link system, with one incoming 3P isolator unit, two 4P ELCB units, 45 SP outgoing MCB units, 1 TP outgoing MCB unit

and a brass link protective circuit.

Manufactured By: Techno Electro Power Industrial W.L.L, Building No. 765, Road 4811, Block No. 948,

Lhassay Area, Manama, Kingdom of Bahrain.

Test Report No: 2007.22.04

Designation: 100A (10+6 Way)

The apparatus which is representative of the designation, supplied drawings and photographs has been evaluated in accordance with:

IEC 61439-3: Edition 1.0, 2012-02, clauses 10.2 to 10.5 & 10.9 to 10.13

Verifications with reference to the tests listed in Annex D of IEC 61439-1: Edition 2.0, 2011-08

1: Strength of material and parts 6/7/8: No verification by testing required

2: Degree of protection of enclosures 9: Dielectric properties

3: Clearances 10: Temperature-rise limits

4: Creepage distances 11: Short-circuit withstand strength

5: Protection against electric shock and integrity of protective circuits 12: Electromagnetic compatibility (EMC)

13: Mechanical operation

The results are shown in the record of tests attached hereto. The values obtained and the general performance is considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as stated on the ratings page(s) of this Certificate. This Certificate applies only to the apparatus tested. Responsibility for conformity of any apparatus having the same or other designations rests with the Manufacturer.

UKAS
PRODUCT
CERTIFICATION

010

R. Kynerd

Certification Engineer Abdul Majid

Certification Officer Robert Hayward

11th February 2022

Date