



EQUIPMENT TYPE APPROVAL

Distribution Customer Use

We hereby confirm that below detailed Equipment is in compliance with the latest relevant regulations and standards, therefore it is **Approved** to be used in Distribution Customer Installation for five years from issuance date, where expiry date is due the Approval Holder shall apply for renewal if needed.

Application Details	
Approval ID: 220316	Approval Holder: <i>Techno Electro Power Industrial</i>
Approval Type: <i>Distribution Customer Use</i>	Valid Till: <i>07 June 2027</i>
Equipment Details	
Category: <i>LV Switchgear & Controlgear Assembly</i>	Trademark: <i>TECHNO</i>
Description: <i>Annexure-A</i>	Designation: <i>Annexure-A</i>
Manufacture Details	
Name: <i>M/s Techno Electro Power Industrial S.P.C.</i>	Country of Origin: <i>Kingdom of Bahrain</i>

Comments:

It is the responsibility of authorized assembler to ensure the following requirements:

- 1) Switching devices and components from M/s Schneider Electric shall be of the same type described in Test Report No. ASTA-TYPE-0001176.*
- 2) Selection and installation of switching devices and components shall be in accordance to relevant standards.*
- 3) Other switching devices and components configurations shall be verified in accordance to relevant standards.*

Signature:

Stamp:

Chief, Engineering Services Section

